

CERTIFICATE

No. P09211218



Accredited Certificate (ref. NA-PROD 001) Order No. 134877 Page 1/3

Product	Conduit for electrical installations
Applicant	Nordisk Wavin A/S Wavinvej 1 DK-8450 Hammel Denmark
Manufacturer	Nordisk Wavin A/S Wavinvej 1 DK-8450 Hammel Denmark
Factory	Nordisk Wavin A/S Wavinvej 1 DK-8450 Hammel Denmark See next page(s)
Ratings	
Trade mark	Wavin
Model / Type Ref.	16
Principal characteristics	Rigid conduits of insulating material. Temperature range: -25°C / + 60°C. Resistance to impact 2J. Resistance to compression 750N. Non-flame propagating conduit. Classification coding 3341. Lead free. PVC conduit VP, outer diameter 16 mm See next page(s)
A sample of the product was tested and found to be in conformity with	INST EN 61386-1:2008 EN 61386-21:2004
Validity	This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.
Additional information	See next page(s)
Additional model(s)	See next page(s)
Date of issue 10-09-2009	
Gen Clorth	

Geir Hørthe

Certification Department

Nemko AS Office address Telephone Internet Fax P.O. Box 73, Blindern Gaustadalléen 30 www.nemko.com +47 22 96 03 30 + 47 22 96 05 50 NO 974404532 N-0314 Oslo, Norway Oslo Enterprise number:



CERTIFICATE

No. P09211218



Order No. 134877 Accredited Certificate (ref. NA-PROD 001) Page 2/3

Product Conduit for electrical installations

Pos. No 1 Model / Type Ref. 20

Trade mark (if different from page 1)

Rating

Principal characteristics Rigid conduits of insulating material.

Temperature range: -25°C / + 60°C.

Resistance to impact 2J. Resistance to compression 750N.

Non-flame propagating conduit. Classification coding 3341.

Lead free. PVC conduit VP, outer diameter 20 mm

Product Conduit for electrical installations

Pos. No 2 Model / Type Ref. 50

Trade mark (if different from page 1)

Rating

Principal characteristics Rigid conduits of insulating material.

Temperature range: -25°C / + 60°C.

Resistance to impact 2J. Resistance to compression 750N.

Non-flame propagating conduit. Classification coding 3341.

Lead free. PVC conduit VP, outer diameter 50 mm

Product Conduit for electrical installations

Pos. No 3 Model / Type Ref. 40

Trade mark (if different from page 1)

Rating

Principal characteristics Rigid conduits of insulating material.

Temperature range: -25°C / + 60°C.

Resistance to impact 2J. Resistance to compression 750N.

Non-flame propagating conduit. Classification coding 3341.

Lead free. PVC conduit VP, outer diameter 40 mm

Date of issue 10-09-2009

Gew Clor Hu Signature Geir Hørthe

Certification Department

Nemko ASOffice addressInternetTelephoneFaxP.O. Box 73, BlindernGaustadalléen 30www.nemko.com+47 22 96 03 30+ 47 22 96 05 50N-0314 Oslo, NorwayOsloEnterprise number:NO 974404532



CERTIFICATE

No. P09211218



134877 Accredited Certificate (ref. NA-PROD 001) Page 3/3

Product Conduit for electrical installations

Pos. No 4 Model / Type Ref. 32

Trade mark (if different from page 1)

Rating

Order No.

Principal characteristics Rigid conduits of insulating material.

Temperature range: -25°C / + 60°C.

Resistance to impact 2J. Resistance to compression 750N.

Non-flame propagating conduit. Classification coding 3341.

Lead free. PVC conduit VP, outer diameter 32 mm

Product Conduit for electrical installations

Pos. No 5 Model / Type Ref. 25

Trade mark (if different from page 1)

Rating

Principal characteristics Rigid conduits of insulating material.

Temperature range: -25°C / + 60°C.

Resistance to impact 2J. Resistance to compression 750N.

Non-flame propagating conduit. Classification coding 3341.

Lead free. PVC conduit VP, outer diameter 25 mm

Date of issue 10-09-2009

Signature Geir Hørthe

Certification Department

Nemko ASOffice addressInternetTelephoneFaxP.O. Box 73, BlindernGaustadalléen 30www.nemko.com+47 22 96 03 30+ 47 22 96 05 50N-0314 Oslo, NorwayOsloEnterprise number:NO 974404532